

**SOLUTIONS**  
**PUMP STATION DESIGN COURSE**  
**DAY 2**

**CONTINUING PROFESSIONAL DEVELOPMENT RESULTS SHEET**


**PUMP STATION DESIGN  
PRACTICAL 3**

**Question 1**

**As sketched at course.**

## PUMP STATION DESIGN PRACTICAL 3

### Question 2



- a) Calculate the friction loss in both pipe sections:

$$h_{f1} = \frac{\lambda_1 L_1 V_1^2}{2gD_1} = \frac{(0,016)(25) \left( \frac{0,098}{\pi \left( \frac{0,35}{2} \right)^2} \right)^2}{2(9,81)(0,35)} = 0,0604 \text{ m}$$

$$h_{f2} = \frac{\lambda_2 L_2 V_2^2}{2gD_2} = \frac{(0,014)(1800) \left( \frac{0,098}{\pi \left( \frac{0,25}{2} \right)^2} \right)^2}{2(9,81)(0,25)} = 20,477 \text{ m}$$

Thus:

$$V_1 = 1,02 \text{ m/s}$$

$$V_2 = 2,0 \text{ m/s}$$

The pressure head downstream of the pump is  $160 + 20,477 + (10 - 0,0604) = 190,417 \text{ m}$   
For a bypass to be activated the pressure needs to drop to a level lower than 10 m. The downstream pressure would then be less than the upstream pressure and the bypass will start to discharge water from up- to downstream to balance the two sides.

Calculate the pressure drop due to the power failure:

$$\Delta h = \frac{-c_p p_0}{\rho g} = \frac{(980)(1000)(2,0)}{(1000)(9,81)} = -199,8 \text{ m}$$

This means that the pressure will drop to a lower level on the downstream side and thus a bypass situated at the pump will be activated i.e. it will open.

- b) I would put it at the pump. Since the pressure drop at the pump will result in a negative pressure on the delivery side an air valve (vacuum function) would work there (instead of bypass).

If the pressure drop was less than  $160 + 20,477 = 180,477 \text{ m}$  then the position on the line should be determined where the gradient will intersect the profile and place the air valve at this location to prevent the vacuum from forming.

## PUMP STATION DESIGN PRACTICAL 3

### Question 3

Two options have been analysed:

**Option 1:** 6 % interest rate and 0 % escalation

**Option 2:** 6% interest rate and 5 % escalation

### Option 1:

<b>Assumptions:</b>	Assume values are end of year values
	Off-peak rate 0.15 R/kW
	Standard 0.25 R/kW
	Peak 0.33 R/kW

Description	Alternative 1	Alternative 2	Units
Capital cost	R 1,200,000.00	R 1,700,000.00	
Additional investment	R 250,000.00	R 0.00	
Pumping head	185	155	m
Pumping time	12	15	hours/day
Flow rate	30	24	l/s
System efficiency	70	71	%
Power	77.78	51.40	kW
Hours off peak	12	14	
Hours standard	0	1	
Hours peak	0	0	
Escalation	0	0	%
Interest rate	6	6	%
Maintenance	2.5	2.5	%

Year	Energy	Maintenance	Energy	Maintenance
1	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
2	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
3	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
4	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
5	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
6	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
7	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
8	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
9	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
10	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
11	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
12	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
13	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
14	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
15	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
16	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
17	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
18	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
19	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
20	R 51,100.99	R 30,000.00	R 42,211.32	R 42,500.00
<b>NPV Year 0</b>	<b>R 586,124.34</b>	<b>R 344,097.64</b>	<b>R 484,160.57</b>	<b>R 487,471.65</b>

<b>Total NPV</b>	<b>R 2,380,221.97</b>	<b>R 2,671,632.22</b>
------------------	-----------------------	-----------------------



## Option 2:

<b>Assumptions:</b>	Assume values are end of year values
	Off-peak rate 0.15 R/kW
	Standard 0.25 R/kW
	Peak 0.33 R/kW

Description	Alternative 1	Alternative 2	Units
Capital cost	R 1,200,000.00	R 1,700,000.00	
Additional investment	R 250,000.00	R 0.00	
Pumping head	185	155	m
Pumping time	12	15	hours/day
Flow rate	30	24	l/s
System efficiency	70	71	%
Power	77.78	51.40	kW
Hours off peak	12	14	
Hours standard	0	1	
Hours peak	0	0	
Escalation	5	5	%
Interest rate	6	6	%
Maintenance	2.5	2.5	%

Year	Energy	Maintenance	Energy	Maintenance
1	R 53,656.04	R 31,500.00	R 44,321.89	R 44,625.00
2	R 56,338.84	R 33,075.00	R 46,537.99	R 46,856.25
3	R 59,155.78	R 34,728.75	R 48,864.88	R 49,199.06
4	R 62,113.57	R 36,465.19	R 51,308.13	R 51,659.02
5	R 65,219.25	R 38,288.45	R 53,873.54	R 54,241.97
6	R 68,480.21	R 40,202.87	R 56,567.21	R 56,954.06
7	R 71,904.23	R 42,213.01	R 59,395.57	R 59,801.77
8	R 75,499.44	R 44,323.66	R 62,365.35	R 62,791.86
9	R 79,274.41	R 46,539.85	R 65,483.62	R 65,931.45
10	R 83,238.13	R 48,866.84	R 68,757.80	R 69,228.02
11	R 87,400.04	R 51,310.18	R 72,195.69	R 72,689.42
12	R 91,770.04	R 53,875.69	R 75,805.47	R 76,323.89
13	R 96,358.54	R 56,569.47	R 79,595.75	R 80,140.09
14	R 101,176.47	R 59,397.95	R 83,575.54	R 84,147.09
15	R 106,235.29	R 62,367.85	R 87,754.31	R 88,354.45
16	R 111,547.05	R 65,486.24	R 92,142.03	R 92,772.17
17	R 117,124.41	R 68,760.55	R 96,749.13	R 97,410.78
18	R 122,980.63	R 72,198.58	R 101,586.59	R 102,281.32
19	R 129,129.66	R 75,808.51	R 106,665.92	R 107,395.38
20	R 135,586.14	R 79,598.93	R 111,999.21	R 112,765.15
<b>NPV Year 0</b>	<b>R 926,582.05</b>	<b>R 543,971.09</b>	<b>R 765,391.34</b>	<b>R 770,625.71</b>

<b>Total NPV</b>	<b>R 2,920,553.13</b>	<b>R 3,236,017.04</b>
------------------	-----------------------	-----------------------

Alternative 1 remains the better alternative of the two analysed based on its NPV which is the lowest